



ATEST HIGIENICZNY

B.BK.60112.0006.2024

HYGIENIC CERTIFICATE

ORYGINAŁ

NATIONAL INSTITUTE OF PUBLIC HEALTH NIH – NATIONAL RESEARCH INSTITUTE

Wyrób / product: **Straight ducts and vent fittings, rectangular/round, including: SPIRO pipes, elbows, bends, tees, fourpieces, reductions, connectors, overlays, offsets, grilles diffusers, pipes, ventilators, air intakes, launchers, bases, pedestals, offsets, caps, dampers, spigots**

Zawierający / containing: galvanized steel and other materials in accordance with the manufacturer's documentation

Przeznaczony do / destined: ventilation and air-conditioning systems of residential buildings, public buildings (including facilities: entities providing medical, service and commercial activities) and industrial facilities

Wymieniony wyżej produkt odpowiada wymaganiom higienicznym przy spełnieniu następujących warunków / the above-named product is acceptable according to hygienic criteria with the following conditions:

The use and manufacture of the products must comply with current regulations applicable to the facility in which they are installed. In the facilities of entities performing medical activities, grilles are used, excluding rooms with increased hygiene requirements (operating rooms, ICU, recovery rooms, etc.). Installation and operation in accordance with the manufacturer's recommendations.

The hygiene certificate does not apply to technical parameters, functional values or assessment of the allergenic properties of the product

Wytwórca / producer:

ECO PROF KLIMA Sp. z o.o.
00-844 Warszawa
ul. Grzybowska 87

Niniejszy dokument wydano na wniosek / this certificate issued for:

ECO PROF KLIMA Sp. z o.o.
00-844 Warszawa
ul. Grzybowska 87



Atest może być zmieniony lub unieważniony po przedstawieniu stosownych dowodów przez którąkolwiek stronę. Niniejszy atest traci ważność po 2029.01.03 lub w przypadku zmian w recepturze albo w technologii wytwarzania wyrobu.

The certificate may be corrected or cancelled after appropriate motivation. The certificate loses its validity after 2029.01.03 or in the case of changes in composition or in technology of production.

Data wydania atestu higienicznego: 12 stycznia 2024

The date of issue of the certificate: 12th January 2024

Kierownik
Zakładu Bezpieczeństwa Zdrowotnego
Środowiska

z mp. M. Jankowska
dr hab. Jolanta Solecka, prof. NIZP PZH-PIB